

NO PARKING FIRE LANE SIGN



SIGN SPECIFICATIONS

Steel: 18 ga. ASTM A-424 Type II
 Color: Red on White, Reflective B/G
 Size: 12" x 18"
 Mounting: Single face with sign installed on each side of the post
 (two signs installed back-to-back)

PIPE SPECIFICATIONS

- 2" I.D. Galv. Pipe
 - 10'6" in length
 - Minimum 2' bury
 * Alternate methods of attaching signs may be approved by the
 Fire Protection Engineer

FUSED PORCELAIN CERAMIC ENAMEL SIGN FOR EXTERIOR USE

* California Vehicle Code Section 22500.1

GUIDELINES FOR AUTHORIZING AND MARKING FIRE LANES ON PRIVATE PROPERTY

1. Only a Fire Department representative has the authority to designate Fire Lanes.
2. The property owner is required to post and maintain Fire Lanes.
3. To post authorized Fire Lanes, install approved "NO PARKING FIRE LANE" signs immediately adjacent to, and visible from, the designated fire lane. (Specific locations and frequency as directed by the Fire Protection Engineer).
4. Signs shall be modeled as identified below:

NO PARKING]-----[4" high, 1/2" stroke width
 FIRE LANE]-----[2" high
 CVC. Sect. 22500.1, CITY ORD. 19.80]-----[1/8" stroke width
 (*Red letters on a white background.)

5. Boundaries of restricted parking areas shall be designated as follows:

Curbs along fire access roads shall be painted traffic red. Such curbs shall have the words 'FIRE LANE - NO PARKING' (all capital letters) stenciled each 50 feet (15240 mm) on both the face and top edges. The stenciled letters shall be 3 inches (76.2 mm) high with a stroke of 1/2 inch (12.7 mm) and be white in color. Fire access lanes not having curbs shall have a 6 inches (152.4 mm) red stripe painted along the edge(s). This red stripe shall have the words 'FIRE LANE- NO PARKING' (all capital letters) stenciled each 50 feet (15240 mm). The stenciled letters shall be 3 inches (76.2 mm) high with a stroke of 1/2 inch (12.7 mm) and be white in color.

6. Violators should be reported to the Mountain View Police Department.